

September 07, 2018

Rob King
Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

RE: Project: DIST BACT 9/5
Pace Project No.: 7063785

Dear Rob King:

Enclosed are the analytical results for sample(s) received by the laboratory on September 05, 2018. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Stu Murrell
stu.murrell@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Warren Booth, Hampton Bays Water District
John Collins, H2M Group
Stella Michaels, Hampton Bays Water District
Paul Ponturo, H2M Group



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: DIST BACT 9/5

Pace Project No.: 7063785

Lab ID	Sample ID	Matrix	Date Collected	Date Received
7063785001	HB27	Drinking Water	09/05/18 09:15	09/05/18 16:30
7063785002	HB2	Drinking Water	09/05/18 07:45	09/05/18 16:30
7063785003	HB3	Drinking Water	09/05/18 08:00	09/05/18 16:30
7063785004	HB4	Drinking Water	09/05/18 08:21	09/05/18 16:30
7063785005	HB5	Drinking Water	09/05/18 08:36	09/05/18 16:30
7063785006	HB6	Drinking Water	09/05/18 08:56	09/05/18 16:30
7063785007	HB7	Drinking Water	09/05/18 09:30	09/05/18 16:30
7063785008	HB8	Drinking Water	09/05/18 09:45	09/05/18 16:30
7063785009	HB9	Drinking Water	09/05/18 07:30	09/05/18 16:30
7063785010	HB10	Drinking Water	09/05/18 10:15	09/05/18 16:30
7063785011	HB11	Drinking Water	09/05/18 10:00	09/05/18 16:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: DIST BACT 9/5

Pace Project No.: 7063785

Lab ID	Sample ID	Method	Analysts	Analytes Reported
7063785001	HB27	SM22 9223B Colilert	NML	2
7063785002	HB2	SM22 9223B Colilert	NML	2
7063785003	HB3	SM22 9223B Colilert	NML	2
7063785004	HB4	SM22 9223B Colilert	NML	2
7063785005	HB5	SM22 9223B Colilert	NML	2
7063785006	HB6	SM22 9223B Colilert	NML	2
7063785007	HB7	SM22 9223B Colilert	NML	2
7063785008	HB8	SM22 9223B Colilert	NML	2
7063785009	HB9	SM22 9223B Colilert	NML	2
7063785010	HB10	SM22 9223B Colilert	NML	2
7063785011	HB11	SM22 9223B Colilert	NML	2

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB27		Lab ID: 7063785001		Collected: 09/05/18 09:15	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.41	mg/L			1		09/05/18 09:15		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB2		Lab ID: 7063785002		Collected: 09/05/18 07:45	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.47	mg/L			1		09/05/18 07:45		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB3		Lab ID: 7063785003		Collected: 09/05/18 08:00	Received: 09/05/18 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.41	mg/L			1		09/05/18 08:00		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25		
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB4		Lab ID: 7063785004		Collected: 09/05/18 08:21	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.40	mg/L			1		09/05/18 08:21		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB5		Lab ID: 7063785005		Collected: 09/05/18 08:36	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.54	mg/L			1		09/05/18 08:36		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB6		Lab ID: 7063785006		Collected: 09/05/18 08:56	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.46	mg/L			1		09/05/18 08:56		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: HB7									
Lab ID: 7063785007									
Collected: 09/05/18 09:30 Received: 09/05/18 16:30 Matrix: Drinking Water									
Field Chlorine and pH									
Analytical Method:									
Field Residual Chlorine	0.59	mg/L			1		09/05/18 09:30		N3
MBIO Total Coliform DW									
Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert									
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25		
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB8		Lab ID: 7063785008		Collected: 09/05/18 09:45	Received: 09/05/18 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	1.07	mg/L			1		09/05/18 09:45		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25		
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB9		Lab ID: 7063785009		Collected: 09/05/18 07:30	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.67	mg/L			1		09/05/18 07:30		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB10 **Lab ID: 7063785010** Collected: 09/05/18 10:15 Received: 09/05/18 16:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH									
Analytical Method:									
Field Residual Chlorine	0.60	mg/L			1		09/05/18 10:15		N3
MBIO Total Coliform DW									
Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert									
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25		
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT 9/5

Pace Project No.: 7063785

Sample: HB11		Lab ID: 7063785011		Collected: 09/05/18 10:00	Received: 09/05/18 16:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.73	mg/L			1		09/05/18 10:00		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	09/05/18 19:25	09/06/18 13:25			
E.coli	Absent				1	09/05/18 19:25	09/06/18 13:25			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: DIST BACT 9/5

Pace Project No.: 7063785

QC Batch: 81963 Analysis Method: SM22 9223B Colilert
 QC Batch Method: SM22 9223B Colilert Analysis Description: TotColDW MBIO Total Coliform
 Associated Lab Samples: 7063785001, 7063785002, 7063785003, 7063785004, 7063785005, 7063785006, 7063785007, 7063785008,
 7063785009, 7063785010, 7063785011

METHOD BLANK: 377095 Matrix: Drinking Water
 Associated Lab Samples: 7063785001, 7063785002, 7063785003, 7063785004, 7063785005, 7063785006, 7063785007, 7063785008,
 7063785009, 7063785010, 7063785011

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
E.coli		Absent		09/06/18 13:25	
Total Coliforms		Absent		09/06/18 13:25	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: DIST BACT 9/5

Pace Project No.: 7063785

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

N3 Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: DIST BACT 9/5

Pace Project No.: 7063785

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
7063785001	HB27		81907		
7063785002	HB2		81907		
7063785003	HB3		81907		
7063785004	HB4		81907		
7063785005	HB5		81907		
7063785006	HB6		81907		
7063785007	HB7		81907		
7063785008	HB8		81907		
7063785009	HB9		81907		
7063785010	HB10		81907		
7063785011	HB11		81907		
7063785001	HB27	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785002	HB2	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785003	HB3	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785004	HB4	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785005	HB5	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785006	HB6	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785007	HB7	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785008	HB8	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785009	HB9	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785010	HB10	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091
7063785011	HB11	SM22 9223B Colilert	81963	SM22 9223B Colilert	82091

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO#: 7063785



Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
Address: P.O. BOX 4013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179

Phone #: _____
Attr: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂	Field Readings pH/Temp	Analysis	Lab No.
9:15 AM 9-5-18	PW	#27	D	-	RO	.41	7.31	Bact w/c	
7:45 AM 9-5-18	PW	#2	D	-	RO	.47	7.26	Bact w/c	
8:00 AM 9-5-18	PW	#3	D	-	RO	.41	7.20	Bact w/c	
5:21 AM 9-5-18	PW	#4	D	-	RO	.40	7.26	Bact w/c	
8:36 AM 9-5-18	PW	#5	D	-	RO	.54	7.30	Bact w/c	
8:56 AM 9-5-18	PW	#6	D	-	RO	.46	7.26	Bact w/c	
9:30 AM 9-5-18	PW	#7	D	-	RO	.59	7.31	Bact w/c	
9:45 AM 9-5-18	PW	#8	D	-	RO	1.07	7.32	Bact w/c	
7:30 AM 9-5-18	PW	#9	D	-	RO	.67	7.20	Bact w/c	
10:15 AM 9-5-18	PW	#10	D	-	RO	.60	7.39	Bact w/c	
9:50 AM 9-5-18	PW	#11	D	-	RO	.73	7.25	Bact w/c	

Remarks:


Sample Request Form
PUBLIC WATER SUPPLIER

Relief Dhan 9-5-18 16:30

- WELL OFF LINE
- WELL RUN TO SYSTEM
- YES NO VOC'S PRESERVED WITH HCI

Date: 9-5-18
 Collected By: K. JUTKILL
 Accepted By: Chy Dhan 14:20
 Cooler Temp: 4.3 °C

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	



Sample Condition Upon Receipt

Client Name: Hayston Bayz

Project

WO#: 7063785

PM: SWM Due Date: 10/05/18

CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: 0.0

Cooler Temperature (°C): 4-3 Cooler Temperature Corrected (°C): 4-3

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: CD 9-5-18

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL/WT DIL		
All containers needing preservation have been checked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #		Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NaOH > 12 Cyanide)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____

