



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605001
Client Sample ID.: S-108065

Federal ID : 5103704
 Collected : 09/21/2018 09:10 AM Point No: S-108065
 Received : 09/21/2018 03:15 PM Location: Well #4-1
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	1.1*		1	mg/L	0.3	09/26/2018 11:46	001 BP4N1/1
Manganese	0.15		1	mg/L	0.3	09/26/2018 11:46	001 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605002
Client Sample ID.: S-108066

Federal ID : 5103704
 Collected : 09/21/2018 09:12 AM Point No: S-108066
 Received : 09/21/2018 03:15 PM Location: Well #4-2
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	2.4*		1	mg/L	0.3	09/26/2018 11:51	002 BP4N1/1
Manganese	0.15		1	mg/L	0.3	09/26/2018 11:51	002 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605003
 Client Sample ID.: 4 FIELD ENTRY POINT

Federal ID : 5103704
 Collected : 09/21/2018 09:13 AM Point No:
 Received : 09/21/2018 03:15 PM Location:
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	1.8*		1	mg/L	0.3	09/26/2018 11:54	003 BP4N1/1
Manganese	0.15		1	mg/L	0.3	09/26/2018 11:54	003 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605004
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 09/21/2018 08:22 AM Point No: S-127163
 Received : 09/21/2018 03:15 PM Location: Well #5-1
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.13		1	mg/L	0.3	09/26/2018 11:57	004 BP4N1/1
Manganese	0.12		1	mg/L	0.3	09/26/2018 11:57	004 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605005
Client Sample ID.: TUTINO - BEFORE FILTER

Federal ID : 5103704
 Collected : 09/21/2018 08:35 AM Point No:
 Received : 09/21/2018 03:15 PM Location:
 Collected By : CLIENT

Sample Comments:
 49 ROMANO DR.

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.39*		1	mg/L	0.3	09/26/2018 11:59	005 BP4N1/1
Manganese	0.040		1	mg/L	0.3	09/26/2018 11:59	005 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605006
 Client Sample ID.: TUTINO - AFTER FILTER

Federal ID : 5103704
 Collected : 09/21/2018 08:35 AM Point No:
 Received : 09/21/2018 03:15 PM Location:
 Collected By : CLIENT

Sample Comments:
 49 ROMANO DR.

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.37*		1	mg/L	0.3	09/26/2018 12:00	006 BP4N1/1
Manganese	0.020		1	mg/L	0.3	09/26/2018 12:00	006 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605007
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 09/21/2018 08:22 AM Point No: S-127163
 Received : 09/21/2018 03:15 PM Location: Well #5-1
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Bromoform	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Chloroform	1.3		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605007
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 09/21/2018 08:22 AM Point No: S-127163
 Received : 09/21/2018 03:15 PM Location: Well #5-1
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	09/24/2018 5:22 PM	007 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Styrene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Toluene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Total Trihalomethanes (Calc.)	1.3	1	ug/L	80	09/24/2018 5:22 PM	007 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Trichlorofluoromethane	<0.50	L1 1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	09/24/2018 5:22 PM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	09/24/2018 5:22 PM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	89%	1	%REC		09/24/2018 5:22 PM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	104%	1	%REC		09/24/2018 5:22 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605009
Client Sample ID.: S-15687

Federal ID : 5103704
 Collected : 09/21/2018 07:51 AM Point No: S-15687
 Received : 09/21/2018 03:15 PM Location: Well #1-1
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:01	009 BP4N1/1
Manganese	0.024		1	mg/L	0.3	09/26/2018 12:01	009 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605010
 Client Sample ID.: S-24848

Federal ID : 5103704
 Collected : 09/21/2018 07:56 AM Point No: S-24848
 Received : 09/21/2018 03:15 PM Location: Well #1-2
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:02	010 BP4N1/1
Manganese	0.41*		1	mg/L	0.3	09/26/2018 12:02	010 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605011
 Client Sample ID.: S-31636

Federal ID : 5103704
 Collected : 09/21/2018 08:00 AM Point No: S-31636
 Received : 09/21/2018 03:15 PM Location: Well #1-3
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:03	011 BP4N1/1
Manganese	0.013		1	mg/L	0.3	09/26/2018 12:03	011 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605012
Client Sample ID.: COMBINED EFF. (MAIN PLANT)

Federal ID : 5103704
 Collected : 09/21/2018 08:03 AM Point No:
 Received : 09/21/2018 03:15 PM Location:
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:04	012 BP4N1/1
Manganese	0.025		1	mg/L	0.3	09/26/2018 12:04	012 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605013
Client Sample ID.: S-50970

Federal ID : 5103704
 Collected : 09/21/2018 09:26 AM Point No: S-50970
 Received : 09/21/2018 03:15 PM Location: Well #2-1
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:05	013 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	09/26/2018 12:05	013 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605014
 Client Sample ID.: S-74071

Federal ID : 5103704
 Collected : 09/21/2018 09:32 AM Point No: S-74071
 Received : 09/21/2018 03:15 PM Location: Well #2-2
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:06	014 BP4N1/1
Manganese	0.021		1	mg/L	0.3	09/26/2018 12:06	014 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605015
Client Sample ID.: 2 FIELD ENTRY POINT

Federal ID : 5103704
 Collected : 09/21/2018 09:33 AM Point No:
 Received : 09/21/2018 03:15 PM Location:
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:07	015 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	09/26/2018 12:07	015 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605016
 Client Sample ID.: S-58350

Federal ID : 5103704
 Collected : 09/21/2018 08:59 AM Point No: S-58350
 Received : 09/21/2018 03:15 PM Location: Well #3-1
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:11	016 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	09/26/2018 12:11	016 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605017
 Client Sample ID.: S-58351

Federal ID : 5103704
 Collected : 09/21/2018 08:47 AM Point No: S-58351
 Received : 09/21/2018 03:15 PM Location: Well #3-2
 Collected By : CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:12	017 BP4N1/1
Manganese	0.038		1	mg/L	0.3	09/26/2018 12:12	017 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946
 Attn To : Rob King

Lab No. : 7065605018
 Client Sample ID.: S-58352

Federal ID : 5103704
 Collected : 09/21/2018 08:53 AM Point No: S-58352
 Received : 09/21/2018 03:15 PM Location: Well #3-3
 Collected By : CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:13	018 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	09/26/2018 12:13	018 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7065605019
Client Sample ID.: 3 FIELD ENTRY POINT

Federal ID : 5103704
 Collected : 09/21/2018 09:00 AM Point No:
 Received : 09/21/2018 03:15 PM Location:
 Collected By : CLIENT

Analytical Method: EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	09/26/2018 12:14	019 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	09/26/2018 12:14	019 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 09/26/2018



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7065605

Laboratory Certifications

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :

7065605

Qualifiers

L1 - Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.



WO#: 7065605



7065605

747

Sample Request Form PUBLIC WATER SUPPLIER

Date: 9-21-18

Collected By: W. Booth

Accepted By: [Signature]

Cooler Temp: 2.6 °C

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCI

Back 1515

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
Address: PO BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
9:10 9-21-18	GW	WELL 4-1	RW	-	S		IRON, MANGANESE	001
9:12 9-21-18	GW	WELL 4-2	RW	-	S		IRON, MANGANESE	002
9:13 9-21-18	GW	4 FIELD ENTRY POINT	RW	-	S		IRON, MANGANESE	003
8:22 9-21-18	GW	WELL 5-1	RW	-	S		IRON, MANGANESE	004
8:35 9-21-18	PW GW	TUTINO - B4 FILTER 49 ROMANO DR	D	-	S .56	7.37	IRON, MANGANESE	005
8:35 9-21-18	PW GW	TUTINO AFTER FILTER 49 ROMANO DR.	D	-	S .36	7.27	IRON, MANGANESE	006
8:27 9-21-18	GW	WELL 5-1	RW	-	S		POC'S	007
8:00 9-21-18	GW	WELL 1-3	RW	-	RO		NITRATE/NITRITE	008

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Remarks: PLEASE MAKE SURE JOHN COLLINS H2M - GET RESULTS FOR THE WELL READS



575 Broad Hollow Rd., Melville, NY 11747
 (631) 694-3040 Fax: (631) 420-8436

Sample Request Form PUBLIC WATER SUPPLIER

WELL OFF LINE

Date: 9-21-18

Collected By: W Booth

Accepted By: [Signature]

Cooler Temp: 2.6 °C

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
 Address: PO BOX 7013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179
 Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
7:57 9-21-18	GW	WELL 1-1	RW	-	S		IRON, MANGANESE	007 008
7:56 9-21-18	GW	WELL 1-2	RW	-	S		IRON, MANGANESE	008 009
8:00 9-21-18	GW	WELL 1-3	RW	-	S		IRON, MANGANESE	009 010
8:03 9-21-18	GW	COMBINED EFF. (MAN PLANT)	RW	-	S		IRON, MANGANESE	010 011
9:26 9-21-18	GW	WELL 2-1	RW	-	S		IRON, MANGANESE	011 012
9:37 9-21-18	GW	WELL 2-2	RW	-	S		IRON, MANGANESE	012 013
9:33 9-21-18	GW	2 FIELD ENTRY POINT	RW	-	S		IRON, MANGANESE	013 014
8:59 9-21-18	GW	WELL 3-1	RW	-	S		IRON, MANGANESE	014 015
8:47 9-21-18	GW	WELL 3-2	RW	-	S		IRON, MANGANESE	015 016
8:53 9-21-18	GW	WELL 3-3	RW	-	S		IRON, MANGANESE	016 017
9:00 9-21-18	GW	3 FIELD ENTRY POINT	RW	-	S		IRON, MANGANESE	017 018

Remarks: PLEASE MAKE SURE JOHN COLLINS H2M GETS RESULTS
FROM WELL FIELDS



Sample Condition Upon Receipt

WO#: 7065605
PM: SWM Due Date: 09/27/18
CLIENT: HBW

Client Name: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____
Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: 0.0
Cooler Temperature (°C): 2.6 Cooler Temperature Corrected (°C): 2.6

Temperature Blank Present: Yes No

Type of Ice: Wet Blue None

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C
USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 9/21/18

Did samples originate in a quarantine zone within the United States: AL, AK, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A		4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for MS/MSD):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		10.
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A		Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		12.
-Includes date/time/ID/Analysis Matrix SL W OIL			
All containers needing preservation have been checked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A		13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>172857466</u>			Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A		
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			Initial when completed: Lot # of added preservative: Date/Time preservative added
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A		14.
KI starch test strips Lot #			Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A		15.
Trip Blank Present:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A		16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A		
Pace Trip Blank Lot # (if applicable): _____			

Field Data Required? Y / N

Date/Time: _____

Client Notification/ Resolution:

Person Contacted: _____

Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.