



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094001
Client Sample ID.: S-50970

Federal ID : 5103704
 Collected : 05/09/2018 08:10 AM Point No: S-50970
 Received : 05/09/2018 04:45 PM Location: Well #2-1
 Collected By : CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	2.4		10	mg/L	10	05/09/2018 10:59	001 BP4U1/1
Nitrate-Nitrite (as N)	2.4		10	mg/L		05/09/2018 10:59	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050	M1	1	mg/L	1	05/09/2018 9:03 PM	001 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 5:53 PM	001 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 5:53 PM	001 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094001
Client Sample ID.: S-50970

Federal ID : 5103704
 Collected : 05/09/2018 08:10 AM Point No: S-50970
 Received : 05/09/2018 04:45 PM Location: Well #2-1
 Collected By : CLIENT

Compound	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Chloroform	1.7		1	ug/L		05/20/2018 5:53 PM	001 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		05/20/2018 5:53 PM	001 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	05/20/2018 5:53 PM	001 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Styrene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Toluene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Total Trihalomethanes (Calc.)	1.7		1	ug/L	80	05/20/2018 5:53 PM	001 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	05/20/2018 5:53 PM	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 5:53 PM	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	99%		1	%REC		05/20/2018 5:53 PM	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	88%		1	%REC		05/20/2018 5:53 PM	001 VG9C1/2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent		1		Absent	05/10/2018 12:45	001 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	001 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094002
Client Sample ID.: S-74071

Federal ID : 5103704
 Collected : 05/09/2018 08:25 AM Point No: S-74071
 Received : 05/09/2018 04:45 PM Location: Well #2-2
 Collected By : CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	3.2		10	mg/L	10	05/09/2018 11:03	002 BP4U1/1
Nitrate-Nitrite (as N)	3.2		10	mg/L		05/09/2018 11:03	002 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:07 PM	002 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 6:19 PM	002 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 6:19 PM	002 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094002
Client Sample ID.: S-74071

Federal ID : 5103704
 Collected : 05/09/2018 08:25 AM Point No: S-74071
 Received : 05/09/2018 04:45 PM Location: Well #2-2
 Collected By : CLIENT

Compound	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Chloroform	0.83		1	ug/L		05/20/2018 6:19 PM	002 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		05/20/2018 6:19 PM	002 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	05/20/2018 6:19 PM	002 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Styrene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Toluene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Total Trihalomethanes (Calc.)	0.83		1	ug/L	80	05/20/2018 6:19 PM	002 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	05/20/2018 6:19 PM	002 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 6:19 PM	002 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	99%		1	%REC		05/20/2018 6:19 PM	002 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	91%		1	%REC		05/20/2018 6:19 PM	002 VG9C1/2

Analytical Method: SM22 9223B Colilert		Prep Method: SM22 9223B Colilert			Prep Date: 05/09/2018 6:45 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/10/2018 12:45	002 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	002 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell
 Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094003
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 05/09/2018 08:45 AM Point No: S-127163
 Received : 05/09/2018 04:45 PM Location: Well #5-1
 Collected By : CLIENT

Sample Comments:
 RUN TO WASTE

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	1.9		10	mg/L	10	05/09/2018 11:04	003 BP4U1/1
Nitrate-Nitrite (as N)	1.9		10	mg/L		05/09/2018 11:04	003 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:10 PM	003 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 6:46 PM	003 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 6:46 PM	003 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094003
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 05/09/2018 08:45 AM Point No: S-127163
 Received : 05/09/2018 04:45 PM Location: Well #5-1
 Collected By : CLIENT

Sample Comments:
 RUN TO WASTE

Carbon tetrachloride	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Chloroform	7.4	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	05/20/2018 6:46 PM	003 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Styrene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Toluene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Total Trihalomethanes (Calc.)	7.4	1	ug/L	80	05/20/2018 6:46 PM	003 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	05/20/2018 6:46 PM	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	05/20/2018 6:46 PM	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	96%	1	%REC	5	05/20/2018 6:46 PM	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	85%	1	%REC	5	05/20/2018 6:46 PM	003 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 05/09/2018 6:45 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/10/2018 12:45	003 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	003 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094004
Client Sample ID.: S-58351

Federal ID : 5103704
 Collected : 05/09/2018 09:10 AM Point No: S-58351
 Received : 05/09/2018 04:45 PM Location: Well #3-2
 Collected By : CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.44		1	mg/L	10	05/09/2018 11:05	004 BP4U1/1
Nitrate-Nitrite (as N)	0.44	M1	1	mg/L		05/09/2018 11:05	004 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:11 PM	004 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 7:12 PM	004 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 7:12 PM	004 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094004
Client Sample ID.: S-58351

Federal ID : 5103704
 Collected : 05/09/2018 09:10 AM Point No: S-58351
 Received : 05/09/2018 04:45 PM Location: Well #3-2
 Collected By : CLIENT

Compound	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Chloroform	1.2		1	ug/L		05/20/2018 7:12 PM	004 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		05/20/2018 7:12 PM	004 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	05/20/2018 7:12 PM	004 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Styrene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Toluene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Total Trihalomethanes (Calc.)	1.2		1	ug/L	80	05/20/2018 7:12 PM	004 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	05/20/2018 7:12 PM	004 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 7:12 PM	004 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	99%		1	%REC		05/20/2018 7:12 PM	004 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	85%		1	%REC		05/20/2018 7:12 PM	004 VG9C1/2

Analytical Method: SM22 9223B Colilert		Prep Method: SM22 9223B Colilert			Prep Date: 05/09/2018 6:45 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/10/2018 12:45	004 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	004 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell
 Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094005
Client Sample ID.: S-58350

Federal ID : 5103704
 Collected : 05/09/2018 09:20 AM Point No: S-58350
 Received : 05/09/2018 04:45 PM Location: Well #3-1
 Collected By : CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.13		1	mg/L	10	05/09/2018 11:11	005 BP4U1/1
Nitrate-Nitrite (as N)	0.13		1	mg/L		05/09/2018 11:11	005 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:13 PM	005 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 7:39 PM	005 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 7:39 PM	005 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094005
Client Sample ID.: S-58350

Federal ID : 5103704
 Collected : 05/09/2018 09:20 AM Point No: S-58350
 Received : 05/09/2018 04:45 PM Location: Well #3-1
 Collected By : CLIENT

Compound	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Chloroform	2.5		1	ug/L		05/20/2018 7:39 PM	005 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		05/20/2018 7:39 PM	005 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	05/20/2018 7:39 PM	005 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Styrene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Toluene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Total Trihalomethanes (Calc.)	2.5		1	ug/L	80	05/20/2018 7:39 PM	005 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	05/20/2018 7:39 PM	005 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 7:39 PM	005 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	98%		1	%REC		05/20/2018 7:39 PM	005 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	89%		1	%REC		05/20/2018 7:39 PM	005 VG9C1/2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/10/2018 12:45	005 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	005 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell
 Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094006
Client Sample ID.: S-58352

Federal ID : 5103704
 Collected : 05/09/2018 09:30 AM Point No: S-58352
 Received : 05/09/2018 04:45 PM Location: Well #3-3
 Collected By : CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.18		1	mg/L	10	05/09/2018 11:12	006 BP4U1/1
Nitrate-Nitrite (as N)	0.18		1	mg/L		05/09/2018 11:12	006 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:14 PM	006 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 8:06 PM	006 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 8:06 PM	006 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094006
Client Sample ID.: S-58352

Federal ID : 5103704
 Collected : 05/09/2018 09:30 AM Point No: S-58352
 Received : 05/09/2018 04:45 PM Location: Well #3-3
 Collected By : CLIENT

Compound	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Chloroform	0.95		1	ug/L		05/20/2018 8:06 PM	006 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		05/20/2018 8:06 PM	006 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	05/20/2018 8:06 PM	006 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Styrene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Toluene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Total Trihalomethanes (Calc.)	0.95		1	ug/L	80	05/20/2018 8:06 PM	006 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	05/20/2018 8:06 PM	006 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:06 PM	006 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	96%		1	%REC		05/20/2018 8:06 PM	006 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	91%		1	%REC		05/20/2018 8:06 PM	006 VG9C1/2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent		1		Absent	05/10/2018 12:45	006 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	006 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell
 Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094007
Client Sample ID.: S-108065

Federal ID : 5103704
 Collected : 05/09/2018 09:45 AM Point No: S-108065
 Received : 05/09/2018 04:45 PM Location: Well #4-1
 Collected By : CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.13		1	mg/L	10	05/09/2018 11:13	007 BP4U1/1
Nitrate-Nitrite (as N)	0.13		1	mg/L		05/09/2018 11:13	007 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:15 PM	007 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 8:32 PM	007 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 8:32 PM	007 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094007
Client Sample ID.: S-108065

Federal ID : 5103704
 Collected : 05/09/2018 09:45 AM Point No: S-108065
 Received : 05/09/2018 04:45 PM Location: Well #4-1
 Collected By : CLIENT

Compound	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Chloroform	4.8		1	ug/L		05/20/2018 8:32 PM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		05/20/2018 8:32 PM	007 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	05/20/2018 8:32 PM	007 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Styrene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Toluene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Total Trihalomethanes (Calc.)	4.8		1	ug/L	80	05/20/2018 8:32 PM	007 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	05/20/2018 8:32 PM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:32 PM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	96%		1	%REC		05/20/2018 8:32 PM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	88%		1	%REC		05/20/2018 8:32 PM	007 VG9C1/2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/10/2018 12:45	007 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	007 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell
 Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 7051094008
Client Sample ID.: S-108066

Attn To : Rob King
 Federal ID : 5103704
 Collected : 05/09/2018 10:00 AM Point No: S-108066
 Received : 05/09/2018 04:45 PM Location: Well #4-2
 Collected By : CLIENT

Sample Comments:
 RUN TO WASTE

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.16		1	mg/L	10	05/09/2018 11:14	008 BP4U1/1
Nitrate-Nitrite (as N)	0.16		1	mg/L		05/09/2018 11:14	008 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/09/2018 9:16 PM	008 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Benzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		05/20/2018 8:59 PM	008 VG9C1/2
Bromoform	<0.50		1	ug/L		05/20/2018 8:59 PM	008 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7051094008
Client Sample ID.: S-108066

Federal ID : 5103704
 Collected : 05/09/2018 10:00 AM Point No: S-108066
 Received : 05/09/2018 04:45 PM Location: Well #4-2
 Collected By : CLIENT

Sample Comments:
 RUN TO WASTE

Carbon tetrachloride	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Chloroform	7.6	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	05/20/2018 8:59 PM	008 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Styrene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Toluene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Total Trihalomethanes (Calc.)	7.6	1	ug/L	80	05/20/2018 8:59 PM	008 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	05/20/2018 8:59 PM	008 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	05/20/2018 8:59 PM	008 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	96%	1	%REC	5	05/20/2018 8:59 PM	008 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	88%	1	%REC	5	05/20/2018 8:59 PM	008 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 05/09/2018 6:45 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/10/2018 12:45	008 SP5T1/1
Total Coliforms	Absent		1		Absent	05/10/2018 12:45	008 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7051094

Laboratory Certifications

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7051094

Qualifiers

M1 - Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 7051094



1747

Sample Request Form PUBLIC WATER SUPPLIER

Date: 5-9-18

Collected By: W Booth

Accepted By: [Signature]

Cooler Temp: 2.3 °C

WELL OFF LINE 4-2, 5-1 to Blow off
1325
WELL RUN TO SYSTEM 2-1, 2-2, 3-1, 3-2, 3-3, -4-1

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
8:10 5-9-18	GW	WELL 2-1	RW	-	RO	6.79/12.92	BACT + POC's, N/N	001
8:25 5-9-18	GW	WELL 2-2	RW	-	RO	6.89/12.46	BACT + POC's, N/N	002
8:45 5-9-18	GW	WELL 5-1	RW	-	RO	6.66/12.52	BACT + POC's, N/N	003
9:10 5-9-18	GW	WELL 3-2	RW	-	RO	6.45/13.22	BACT + POC's, N/N	004
9:20 5-9-18	GW	WELL 3-1	RW	-	RO	6.68/12.12	BACT + POC's, N/N	005
9:30 5-9-18	GW	WELL 3-3	RW	-	RO	6.62/12.22	BACT + POC's, N/N	006
9:45 5-9-18	GW	WELL 4-1	RW	-	RO	6.44/12.72	BACT + POC's, N/N	007
9:00 5-9-18	GW	WELL 4-2	RW	-	RO	6.47/12.52	BACT + POC's, N/N	008
Remarks:								

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

YES NO VOC'S PRESERVED WITH HCl

Back 645



Sample Condition Upon Receipt

Client Name: FBG

Project **WO#: 7051094**
 PM SWM Due Date: 06/08/18
 CL ENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____
 Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: PH091 Correction Factor: 0.0

Cooler Temperature (°C): 2.3 Cooler Temperature Corrected (°C): 2.3

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: Ed 5/9/18

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
* -Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL <u>WT</u> OIL			
All containers needing preservation have been checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #			Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NAOH > 12 Cyanide)	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: <u>VOA</u> , Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #			
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):			

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: