



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746001
Client Sample ID.: S-15687

Federal ID : 5103704
 Collected : 10/03/2018 08:00 AM Point No: S-15687
 Received : 10/03/2018 05:00 PM Location: Well #1-1
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/12/2018 10:30	001 VG9C1/2
Bromoform	<0.50		1	ug/L		10/12/2018 10:30	001 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Chloroform	0.88		1	ug/L		10/12/2018 10:30	001 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/12/2018 10:30	001 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/12/2018 10:30	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746001
Client Sample ID.: S-15687

Federal ID : 5103704
 Collected : 10/03/2018 08:00 AM Point No: S-15687
 Received : 10/03/2018 05:00 PM Location: Well #1-1
 Collected By : CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Methyl-tert-butyl ether	<0.50	1		ug/L	10	10/12/2018 10:30	001 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Styrene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Toluene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Total Trihalomethanes (Calc.)	0.88	1		ug/L	80	10/12/2018 10:30	001 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	10/12/2018 10:30	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	10/12/2018 10:30	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	91%	1		%REC		10/12/2018 10:30	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	93%	1		%REC		10/12/2018 10:30	001 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent	1			Absent	10/04/2018 12:30	001 SP5T1/1
Total Coliforms	Absent	1			Absent	10/04/2018 12:30	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746002
Client Sample ID.: S-24848

Federal ID : 5103704
 Collected : 10/03/2018 08:10 AM Point No: S-24848
 Received : 10/03/2018 05:00 PM Location: Well #1-2
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/12/2018 10:58	002 VG9C1/2
Bromoform	<0.50		1	ug/L		10/12/2018 10:58	002 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Chloroform	2.7		1	ug/L		10/12/2018 10:58	002 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/12/2018 10:58	002 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/12/2018 10:58	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746002
Client Sample ID.: S-24848

Federal ID : 5103704
 Collected : 10/03/2018 08:10 AM Point No: S-24848
 Received : 10/03/2018 05:00 PM Location: Well #1-2
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	10/12/2018 10:58	002 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Styrene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Toluene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Total Trihalomethanes (Calc.)	2.7	1	ug/L	80	10/12/2018 10:58	002 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	10/12/2018 10:58	002 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	10/12/2018 10:58	002 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	91%	1	%REC		10/12/2018 10:58	002 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	93%	1	%REC		10/12/2018 10:58	002 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/04/2018 12:30	002 SP5T1/1
Total Coliforms	Absent		1		Absent	10/04/2018 12:30	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746003
Client Sample ID.: S-31636

Federal ID : 5103704
 Collected : 10/03/2018 08:20 AM Point No: S-31636
 Received : 10/03/2018 05:00 PM Location: Well #1-3
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/12/2018 11:26	003 VG9C1/2
Bromoform	<0.50		1	ug/L		10/12/2018 11:26	003 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Chloroform	<0.50		1	ug/L		10/12/2018 11:26	003 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/12/2018 11:26	003 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/12/2018 11:26	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746003
Client Sample ID.: S-31636

Federal ID : 5103704
 Collected : 10/03/2018 08:20 AM Point No: S-31636
 Received : 10/03/2018 05:00 PM Location: Well #1-3
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	10/12/2018 11:26	003 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Styrene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Toluene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	10/12/2018 11:26	003 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	10/12/2018 11:26	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	10/12/2018 11:26	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	91%	1	%REC		10/12/2018 11:26	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	94%	1	%REC		10/12/2018 11:26	003 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/04/2018 12:30	003 SP5T1/1
Total Coliforms	Absent		1		Absent	10/04/2018 12:30	003 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 7066746004
Client Sample ID.: S-15687/24848/31636

Attn To : Rob King
 Federal ID : 5103704
 Collected : 10/03/2018 08:35 AM Point No: S-
 Received : 10/03/2018 05:00 PM Location: Well #1-1/1-2/1-3
 Collected By : CLIENT

Sample Comments:
 COMBINED EFF WELLS 1-2, 1-2, 1-3

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/12/2018 11:54	004 VG9C1/2
Bromoform	<0.50		1	ug/L		10/12/2018 11:54	004 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Chloroform	<0.50		1	ug/L		10/12/2018 11:54	004 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/12/2018 11:54	004 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/12/2018 11:54	004 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746004
Client Sample ID.: S-15687/24848/31636

Federal ID : 5103704
 Collected : 10/03/2018 08:35 AM Point No: S-
 Received : 10/03/2018 05:00 PM Location: Well #1-1/1-2/1-3
 Collected By : CLIENT

Sample Comments:
 COMBINED EFF WELLS 1-2, 1-2, 1-3

Compound	Concentration	Qualifier	D.F.	Units	Limit	Analyzed	Container
Ethylbenzene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Methyl-tert-butyl ether	<0.50	1		ug/L	10	10/12/2018 11:54	004 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Styrene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Toluene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1		ug/L	80	10/12/2018 11:54	004 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	10/12/2018 11:54	004 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	10/12/2018 11:54	004 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%	1		%REC		10/12/2018 11:54	004 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	94%	1		%REC		10/12/2018 11:54	004 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent		1		Absent	10/04/2018 12:30	004 SP5T1/1
Total Coliforms	Absent		1		Absent	10/04/2018 12:30	004 SP5T1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746005
Client Sample ID.: S-50970

Federal ID : 5103704
 Collected : 10/03/2018 09:00 AM Point No: S-50970
 Received : 10/03/2018 05:00 PM Location: Well #2-1
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/13/2018 12:22	005 VG9C1/2
Bromoform	<0.50		1	ug/L		10/13/2018 12:22	005 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Chloroform	1.1		1	ug/L		10/13/2018 12:22	005 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/13/2018 12:22	005 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/13/2018 12:22	005 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746005
Client Sample ID.: S-50970

Federal ID : 5103704
 Collected : 10/03/2018 09:00 AM Point No: S-50970
 Received : 10/03/2018 05:00 PM Location: Well #2-1
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	10/13/2018 12:22	005 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Styrene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Toluene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Total Trihalomethanes (Calc.)	1.1	1	ug/L	80	10/13/2018 12:22	005 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	10/13/2018 12:22	005 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	10/13/2018 12:22	005 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	92%	1	%REC		10/13/2018 12:22	005 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	94%	1	%REC		10/13/2018 12:22	005 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/04/2018 12:30	005 SP5T1/1
Total Coliforms	Absent		1		Absent	10/04/2018 12:30	005 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746006
Client Sample ID.: S-74071

Federal ID : 5103704
 Collected : 10/03/2018 09:10 AM Point No: S-74071
 Received : 10/03/2018 05:00 PM Location: Well #2-2
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/13/2018 12:50	006 VG9C1/2
Bromoform	<0.50		1	ug/L		10/13/2018 12:50	006 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Chloroform	0.63		1	ug/L		10/13/2018 12:50	006 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/13/2018 12:50	006 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/13/2018 12:50	006 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746006
Client Sample ID.: S-74071

Federal ID : 5103704
 Collected : 10/03/2018 09:10 AM Point No: S-74071
 Received : 10/03/2018 05:00 PM Location: Well #2-2
 Collected By : CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Methyl-tert-butyl ether	<0.50	1		ug/L	10	10/13/2018 12:50	006 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Styrene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Toluene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Total Trihalomethanes (Calc.)	0.63	1		ug/L	80	10/13/2018 12:50	006 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	10/13/2018 12:50	006 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	10/13/2018 12:50	006 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%	1		%REC		10/13/2018 12:50	006 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	93%	1		%REC		10/13/2018 12:50	006 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent	1			Absent	10/04/2018 12:30	006 SP5T1/1
Total Coliforms	Absent	1			Absent	10/04/2018 12:30	006 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746007
Client Sample ID.: S-58350

Federal ID : 5103704
 Collected : 10/03/2018 10:20 AM Point No: S-58350
 Received : 10/03/2018 05:00 PM Location: Well #3-1
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/13/2018 1:18 AM	007 VG9C1/2
Bromoform	<0.50		1	ug/L		10/13/2018 1:18 AM	007 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Chloroform	2.1		1	ug/L		10/13/2018 1:18 AM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/13/2018 1:18 AM	007 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746007
Client Sample ID.: S-58350

Federal ID : 5103704
 Collected : 10/03/2018 10:20 AM Point No: S-58350
 Received : 10/03/2018 05:00 PM Location: Well #3-1
 Collected By : CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Methyl-tert-butyl ether	<0.50	1		ug/L	10	10/13/2018 1:18 AM	007 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Styrene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Toluene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Total Trihalomethanes (Calc.)	2.1	1		ug/L	80	10/13/2018 1:18 AM	007 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	10/13/2018 1:18 AM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	10/13/2018 1:18 AM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	89%	1		%REC		10/13/2018 1:18 AM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	92%	1		%REC		10/13/2018 1:18 AM	007 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent	1			Absent	10/04/2018 12:30	007 SP5T1/1
Total Coliforms	Absent	1			Absent	10/04/2018 12:30	007 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746008
Client Sample ID.: S-58351

Federal ID : 5103704
 Collected : 10/03/2018 10:00 AM Point No: S-58351
 Received : 10/03/2018 05:00 PM Location: Well #3-2
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/13/2018 1:46 AM	008 VG9C1/2
Bromoform	<0.50		1	ug/L		10/13/2018 1:46 AM	008 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Chloroform	2.0		1	ug/L		10/13/2018 1:46 AM	008 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/13/2018 1:46 AM	008 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746008
Client Sample ID.: S-58351

Federal ID : 5103704
 Collected : 10/03/2018 10:00 AM Point No: S-58351
 Received : 10/03/2018 05:00 PM Location: Well #3-2
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	10/13/2018 1:46 AM	008 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Styrene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Toluene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Total Trihalomethanes (Calc.)	2.0	1	ug/L	80	10/13/2018 1:46 AM	008 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	10/13/2018 1:46 AM	008 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	10/13/2018 1:46 AM	008 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	92%	1	%REC		10/13/2018 1:46 AM	008 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	92%	1	%REC		10/13/2018 1:46 AM	008 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/04/2018 12:30	008 SP5T1/1
Total Coliforms	Absent		1		Absent	10/04/2018 12:30	008 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746009
Client Sample ID.: S-58352

Federal ID : 5103704
 Collected : 10/03/2018 10:10 AM Point No: S-58352
 Received : 10/03/2018 05:00 PM Location: Well #3-3
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/13/2018 2:14 AM	009 VG9C1/2
Bromoform	<0.50		1	ug/L		10/13/2018 2:14 AM	009 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Chloroform	1.1		1	ug/L		10/13/2018 2:14 AM	009 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/13/2018 2:14 AM	009 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746009
Client Sample ID.: S-58352

Federal ID : 5103704
 Collected : 10/03/2018 10:10 AM Point No: S-58352
 Received : 10/03/2018 05:00 PM Location: Well #3-3
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	10/13/2018 2:14 AM	009 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Styrene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Toluene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Total Trihalomethanes (Calc.)	1.1	1	ug/L	80	10/13/2018 2:14 AM	009 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	10/13/2018 2:14 AM	009 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	10/13/2018 2:14 AM	009 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%	1	%REC		10/13/2018 2:14 AM	009 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	91%	1	%REC		10/13/2018 2:14 AM	009 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/04/2018 12:30	009 SP5T1/1
Total Coliforms	Absent		1		Absent	10/04/2018 12:30	009 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746010
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 10/03/2018 09:40 AM Point No: S-127163
 Received : 10/03/2018 05:00 PM Location: Well #5-1
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/13/2018 2:42 AM	010 VG9C1/2
Bromoform	<0.50		1	ug/L		10/13/2018 2:42 AM	010 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Chlorodifluoromethane	<0.50	L1,N3	1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Chloroform	2.2		1	ug/L		10/13/2018 2:42 AM	010 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/13/2018 2:42 AM	010 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7066746010
Client Sample ID.: S-127163

Federal ID : 5103704
 Collected : 10/03/2018 09:40 AM Point No: S-127163
 Received : 10/03/2018 05:00 PM Location: Well #5-1
 Collected By : CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Methyl-tert-butyl ether	<0.50	1		ug/L	10	10/13/2018 2:42 AM	010 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Styrene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Toluene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Total Trihalomethanes (Calc.)	2.2	1		ug/L	80	10/13/2018 2:42 AM	010 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	10/13/2018 2:42 AM	010 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	10/13/2018 2:42 AM	010 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%	1		%REC		10/13/2018 2:42 AM	010 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	89%	1		%REC		10/13/2018 2:42 AM	010 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/03/2018 6:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent	1			Absent	10/04/2018 12:30	010 SP5T1/1
Total Coliforms	Absent	1			Absent	10/04/2018 12:30	010 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7066746

Laboratory Certifications

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7066746

Qualifiers

L1 - Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

Sample Request Form PUBLIC WATER SUPPLIER

WO#: 7066746



Client Info: HAMPTON BAYS WATER DISTRICT
P.O. BOX 1013
Name or Code: HAMPTON BAYS, NEW YORK 11946
Address: (631) 728-0179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Date: 10-3-18

Collected By: W Booth

Accepted By: Ed Booth

Cooler Temp: 3.3 °C

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
8:00 10-3-18	GW	WELL 1-1	RW	-	RO		BACT + POC	001
8:10 10-3-18	GW	WELL 1-2	RW	-	RO		BACT + POC	002
8:20 10-3-18	GW	WELL 1-3	RW	-	RO		BACT + POC	003
8:35 10-3-18	GW	Comb. EFF. 1-1, 1-2, 1-3	RW	-	RO		BACT + POC	004
9:00 10-3-18	GW	WELL 2-1	RW	-	RO		BACT + POC	005
9:10 10-3-18	GW	WELL 2-2	RW	-	RO		BACT + POC	006
10:20 10-3-18	GW	WELL 3-1	RW	-	RO		BACT + POC	007
10:00 10-3-18	GW	WELL 3-2	RW	-	RO		BACT + POC	008
10:10 10-3-18	GW	WELL 3-3	RW	-	RO		BACT + POC	009
10:30	GW	WELL 4-1	RW	-	RO		BACT + POC	
10:30	GW	WELL 4-2	RW	-	RO		BACT + POC	
Remarks: 1408 10-3-18	GW	WELL 5-1	RW	-	RO		BACT + POC	010



Sample Condition Upo

WO#: 7066746

PM: SWM Due Date: 11/02/18
CLIENT: HBW

Client Name: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #:
Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Type of Ice: Wet Blue None

Thermometer Used: TH091

Correction Factor: 0.0

Cooler Temperature (C): 3.3 Cooler Temperature Corrected (C): 3.3

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 10/3/18

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 16 rows and 3 columns. Columns include checkboxes for 'Yes', 'No', 'N/A', and a 'COMMENTS' column. Rows cover various custody and analysis criteria.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: