



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King

Lab No. : 7068926001
Client Sample ID.: S-108066

Federal ID : 5103704
 Collected : 10/24/2018 10:36 AM Point No: S-108066
 Received : 10/24/2018 01:45 PM Location: Well #4-2
 Collected By : CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/25/2018 10:00	001 VG9C1/2
Bromoform	<0.50		1	ug/L		10/25/2018 10:00	001 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Chloroform	9.2		1	ug/L		10/25/2018 10:00	001 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/25/2018 10:00	001 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/25/2018 10:00	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 7068926001
Client Sample ID.: S-108066

Attn To : Rob King
 Federal ID : 5103704
 Collected : 10/24/2018 10:36 AM Point No: S-108066
 Received : 10/24/2018 01:45 PM Location: Well #4-2
 Collected By : CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	10/25/2018 10:00	001 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Styrene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Toluene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Total Trihalomethanes (Calc.)	9.2	1	ug/L	80	10/25/2018 10:00	001 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	10/25/2018 10:00	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	10/25/2018 10:00	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	96%	1	%REC		10/25/2018 10:00	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	97%	1	%REC		10/25/2018 10:00	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7068926

Laboratory Certifications

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
7068926

Qualifiers

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 7068926



7068926

Sample Request Form PUBLIC WATER SUPPLIER

WELL OFF LINE

Date: 10-24-18

Collected By: W. B. [Signature]

Accepted By: [Signature]

Cooler Temp: 2.6 °C

10/24/18

1345 WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Back 1626

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT

Address: P.O. BOX 1013

HAMPTON BAYS, NEW YORK 11946

(631) 728-0179

Phone #: _____

Attn: _____

Proj. # or (Name): _____

Bill To: _____

Copies To: _____

Sample Info:

Date/Time Collected: 10:36 10-24-18

Sample Type: GW

Location: WELL 4-2

Origin: RW

Treatment Type: -

Purpose: RE

Field Readings Cl₂ pH/Temp

Analysis: POC's

Lab No. 001

Sample Types

- PW - Potable Water
- GW - Groundwater
- SW - Surface Water
- WW - Waste Water
- AQ - Aqueous
- S - Soil

Purpose

- RO - Routine
- RE - Resample
- S - Special

Origin

- D - Distribution
- RW - Raw Well
- TW - Treated Well
- T - Tank
- MW - Monitoring Well
- I - Influent
- E - Effluent

Treatment Types

- AST - Air Stripper
- GAC - Granular Activated Charcoal
- N - Nitrate Removal Plant
- FE - Iron Removal Plant
- O - Other

Remarks:



Sample Condition Upon Receipt

Client Name: HBW

Project

WO#: **7068926**

PM: SWM Due Date: 11/02/18

CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____
Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: 0.0

Cooler Temperature (°C): 2.6 Cooler Temperature Corrected (°C): 2.6

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: SWM 11/24/18

Did samples originate in a quarantine zone within the United States. AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL WT OIL			
All containers needing preservation have been checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #			Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH >9 Sultide, NAOH > 12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #			
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):			

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time: _____

Comments/ Resolution:

