

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King
 Federal ID : 5103704

Lab Project No. : 7076045

Received :01/09/2019 4:40
 Sample Type :Drinking Water

Date Reported:01/10/2019

| Lab Number | Location | Collected | Units | E.coli | Total Coliforms | Field Residual Chlorine |
|-------------------|-------------------|----------------------|---------------|----------------------|----------------------|-------------------------|
| | | | Method | N/A | N/A | mg/L |
| | | | Limits | SM22 9223B Colilert | SM22 9223B Colilert | |
| | | | | Absent | Absent | 4 |
| 7076045001 | HB12 | 1/9/2019 8:00:00 AM | | Absent | Absent | 0.41 |
| Routine | M. Layburn | Collected by: CLIENT | Analysis Time | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 8:00:00 AM |
| Distribution | Squires Pond Rd. | | | | | |
| 7076045002 | HB13 | 1/9/2019 8:15:00 AM | | Absent | Absent | 0.82 |
| Routine | H.B. Bagel | Collected by: CLIENT | Analysis Time | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 8:15:00 AM |
| Distribution | W. Montauk Hwy. | | | | | |
| 7076045003 | HB28 | 1/9/2019 8:31:00 AM | | Absent | Absent | 0.73 |
| Routine | Huebner | Collected by: CLIENT | Analysis Time | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 8:31:00 AM |
| Distribution | Oakwood Rd. | | | | | |
| 7076045004 | HB29 | 1/9/2019 8:45:00 AM | | Absent | Absent | 0.69 |
| Routine | McFarland | Collected by: CLIENT | Analysis Time | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 8:45:00 AM |
| Distribution | Ridgewood La. | | | | | |
| 7076045005 | HB16 | 1/9/2019 9:00:00 AM | | Absent | Absent | 0.67 |
| Routine | Spellman's Marine | Collected by: CLIENT | Analysis Time | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 9:00:00 AM |
| Distribution | Rampasture Rd. | | | | | |
| 7076045006 | HB31 | 1/9/2019 9:30:00 AM | | Absent | Absent | 0.39 |
| Routine | C. Morgan | Collected by: CLIENT | Analysis Time | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 9:30:00 AM |
| Distribution | | | | | | |

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

| Treatments | |
|-----------------------------|------------------------|
| A = Air Stripper Tower | G = Granular Activated |
| FM = Iron/Manganese Removal | |
| N = Nitrate Removal | O = Other |

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Stu Murrell
 Stu Murrell

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests requested.

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Rob King
 Federal ID : 5103704

Lab Project No. : 7076045

Received :01/09/2019 4:40
 Sample Type :Drinking Water

Date Reported:01/10/2019

| Lab Number | Location | Collected | Units | E.coli | Total Coliforms | Field Residual Chlorine |
|-------------------|---------------------|----------------------|---------------|----------------------|----------------------|-------------------------|
| | | | Method | N/A | N/A | mg/L |
| | | | Limits | SM22 9223B Colilert | SM22 9223B Colilert | |
| 7076045007 | HB25 | 1/9/2019 10:00:00 | | Absent | Absent | 4 |
| Routine | K. Springer | Collected by: CLIENT | Analysis Time | Absent | Absent | 0.37 |
| Distribution | Maple Ave. | | | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 10:00:00 AM |
| 7076045008 | | 1/9/2019 10:15:00 | | Absent | Absent | 0.42 |
| | | Collected by: CLIENT | Analysis Time | Absent | Absent | 0.42 |
| | | | | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 10:15:00 AM |
| 7076045009 | HB21 | 1/9/2019 10:30:00 | | Absent | Absent | 0.72 |
| Routine | H.B. Fire Dept. | Collected by: CLIENT | Analysis Time | Absent | Absent | 0.72 |
| Distribution | Montauk Hwy. | | | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 10:30:00 AM |
| 7076045010 | HB5A | 1/9/2019 10:45:00 | | Absent | Absent | 0.40 |
| Routine | Sunday's By The Bay | Collected by: CLIENT | Analysis Time | Absent | Absent | 0.40 |
| Distribution | Dune Rd. | | | 1/10/2019 1:30:00 PM | 1/10/2019 1:30:00 PM | 1/9/2019 10:45:00 AM |

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Treatments

| | |
|-----------------------------|------------------------|
| A = Air Stripper Tower | G = Granular Activated |
| FM = Iron/Manganese Removal | |
| N = Nitrate Removal | O = Other |

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Stu Murrell
 Stu Murrell



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com


WorkOrder :
7076045

Laboratory Certifications

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

WO#: 7076045



7076045

11747
36

Sample Request Form PUBLIC WATER SUPPLIER

Date: 1-9-19

Collected By: *K. J. [Signature]*

Accepted By: *[Signature]*

Cooler Temp: 4.6 °C

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HGI

Client Info: Name or Code: HAMPTON BAYS WATER DISTRICT

Address: PO. BOX 1013

HAMPTON BAYS, NEW YORK 11946

(631) 728-0179

Phone #: _____

Attn: _____

Proj. # or (Name): _____

Bill To: _____

Copies To: _____

| Sample Types | Purpose | Origin | Treatment Types |
|--------------------|---------------|----------------------|-----------------------------------|
| PW - Potable Water | RO - Routine | D - Distribution | AST - Air Stripper |
| GW - Groundwater | RE - Resample | RW - Raw Well | GAC - Granular Activated Charcoal |
| SW - Surface Water | S - Special | TW - Treated Well | N - Nitrate Removal Plant |
| WW - Waste Water | | T - Tank | FE - Iron Removal Plant |
| AQ - Aqueous | | MW - Monitoring Well | O - Other |
| S - Soil | | I - Influent | |
| | | E - Effluent | |

Sample Info:

| Date/Time Collected: | Sample Type | Location | Origin | Treatment Type | Purpose | Field Readings Cl ₂ pH/Temp | Analysis | Lab No. |
|----------------------|-------------|----------|--------|----------------|---------|---|------------------------|---------|
| 1-9-19 9:00 | PW | #12 | D | - | RO | 0.41 | BACT w/Cl ₂ | |
| 1-9-19 8:15 | PW | #13 | D | - | RO | 0.82 | BACT w/Cl ₂ | |
| 1-9-19 8:31 | PW | #28 | D | - | RO | 0.73 | BACT w/Cl ₂ | |
| 1-9-19 8:45 | PW | #29 | D | - | RO | 0.69 | BACT w/Cl ₂ | |
| 1-9-19 9:00 | PW | #16 | D | - | RO | 0.67 | BACT w/Cl ₂ | |
| 1-9-19 9:30 | PW | #31 | D | - | RO | 0.39 | BACT w/Cl ₂ | |
| 1-9-19 10:00 | PW | #25 | D | - | RO | 0.37 | BACT w/Cl ₂ | |
| 1-9-19 10:15 | PW | #33 | D | - | RO | 0.42 | BACT w/Cl ₂ | |
| 1-9-19 10:30 | PW | #21 | D | - | RO | 0.72 | BACT w/Cl ₂ | |
| 1-9-19 10:45 | PW | #52 | D | - | RO | 0.40 | BACT w/Cl ₂ | |

Remarks:

Back At 1690



Sample Condition Upon Receipt

WO#: 7076045

Client Name: HBW

Project: PM: SWM Due Date: 02/08/19 CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: 0.0 Cooler Temperature (C): 4.6 Cooler Temperature Corrected (C): 4.6

Temp should be above freezing to 6.0C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 1/9/19

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? YES NO

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 16 rows and 3 columns. Columns: Question, Yes/No/N/A, and Comments. Row 12 includes handwritten note: 'Time of collection taken from Bottles'. Row 13 includes checkboxes for HNO3, H2SO4, NaOH, HCl.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: